







Table of Contents

Table of Contents	Page 1
Approvals	Page 1
Attention	Page 1
Specification	Page 2
Installation Position	Page 3
Mounting	Page 3
Wiring	Page 4
Painting Valve	Page 4
Protection from Radiant Heat	Page 4
Dimensions	Page 5
Valve Leakage Test	Page 6
Flow Curve	_
Accessories & Replacement	



Approvals



CSA Certified: File No. 1010989

ANSI Z21.21 / CSA 6.5 C/I Marking **CGA 3.9**

Attention



The installation and maintenance of this product must be done under the supervision of an experienced and trained specialist. Never perform work if gas pressure or power is applied, or in the presence of an open flame.



Check the ratings in the specifications verify sure that they are suitable for your application.



Please read the instruction beforeinstalling or operating. Keep the instruction in a safe place. You find the instruction also at www. dungs.com If these instructions are not heeded, the result may be personal injury or damage to property.



On completion of work on the safety shutoff valve, perform a leakage and function test.



Any adjustment and applicationspecific adjustment values must be made in accordance with the equipment manufacturers instructions.

IFGC CSA ANSI NFPA

This product is intended for installations covered by, but not limited to, the following fuel gas codes: CSA B149.1 (for Canada), the International Fuel Gas Code, and NFPA 54 or the following equipment codes and standards: CSA B149.3 (for Canada) or NFPA 37.

Warning: During normal operation, coil is getting hot. (max.

176 °F / 80 °C)

Explanation of symbols

= Action 1, 2, 3 ...

= Instruction

MC • Karl Dungs, Inc. • HPSV 10020/604 • Edition 2017.05 • P/N 264712

Specification

HPSV 10020/604

Normally closed automatic shutoff valve. Fast opening, fast closing.











100 PSI (689 kPa) factory rating 60 PSI (413 kPa) as per ANSI Z21.21/ CSA 6.5 C/I and 100 PSI as per CGA 3.9

Burst Pressure Rating 500 PSI (3447 kPa)

Electrical Ratings Available 24 VDC Power Consumption



Ambient / Fluid Service Temperature

-20 °F to +140 °F CSA -29 °C to +60 °C Factory +5 °F to +140 °F -15 °C to +60 °C

Storage Temperature

Gases

-40 °F to +185 °F -40 °C to +85 °C

Dry, natural gas, propane, butane;

other noncorrosive gases as well as

waste-gases and bio-gases contain-

ing up to a maximum 0.1 % by volume

Intended for gaseous fuels only. Cannot be used with non-compressible

(A "dry" gas has a dew point lower

than + 15 °F and its relative humidity

(1000 ppm) of H₂S, dry.

fluids (liquids) of any kind.

Degree of Protection

NEMA 4/IP65

45 W

Suitable for hazardous locations Class I, Division 2, Groups C and D, Temperature code T4A.



Operating Time

100 % duty cycle **Closing Time**

Opening Time

Gas Connection Type

2" flat face flange per ANSI B16.5 Class 150



is less than 60 %.) Materials in contact with Gas

Housing: Anodized Aluminium and Steel, free of non-ferrous metals Sealings on valve seats: NBR-based rubber.



Vibration Resistance

According to MIL 810 Profile Vibration





Strainer

Built-in 1 mm stainless steel mesh strainer, installed upstream of the valve seat.


Electrical Connection

Quick disconnect according to MIL ACS02A-10SL-04P-003 According to CSA C22.1 Part 1

Installation Position

Installation Position

Safety shutoff valve from vertically upright to horizontal.




Mounting

HPSV 10020/604 Flanged Mounting Procedure

- 1. Only install the HPSV 10020/604 safety valve downstream of a 50 micron max. gas filter and with the gas flow matching the direction indicated by the arrows on the casting.
- 2. Mount the HPSV 10020/604 to a flat face B16.5 flange with the solenoid vertical to horizontal.
- 3.Insert proper flange seal.
- 4. Insert studs, tighten in a crisscross pattern to ensure uniform tightness.
- 5.Do not overtighten studs. Follow the maximum torque values listed.
- 6. After installation is complete, perform a leak test. (see "Valve Leakage Test")

A manual shutoff valve and a leak test connection shall be installed downstream of the valve in order to provide for proper valve leakage testing.







Stress free assembling!



Recommended Torque for Studs	Studs	T _{max}
	M16 X 65 mm (DIN 939)	1327 [lb-in] (150 Nm)

Recommended Installation HPSV 10020/604 HPSV 10020/604 Safety Shutoff Valve Safety Shutoff Valve Manual Shutoff Valve Inlet Pressure = 50 micron max. gas filter Leak Test Leak Test Connection Connection

Wiring

Wiring the HPSV 10020/604

- 1. Disconnect all power to the leads before wiring to prevent electrical shock and equipment damage.
- 2. Run pigtails through conduit to a splice box.
- 3. Connect pigtails acc. to "Electrical Connection".
- 4. The conduit shall be suitable for 24 VDC and capable of at least 2 A and rated for at least 75 °C (167 °F).




All wiring must comply with local electrical codes and regulations.

Label all wires prior to disconnection when servicing valves. Wiring errors can cause improper and dangerous operation. Verify proper operation after servicing.

No protection elements (diode, fuse, VDR) are implemented in the valve. No rectifier or polarization diodes are applied. There is a direct connection to the solenoid windings. Therefore, the coil is not polarity sensitive.

Electrical Connection

18" Pigtails with 1/2" NPT conduit Connections are not polarity sensitive.



Note: When installed in hazardous locations, the wiring shall be Ex ia, Ex ib, Ex ic, or Nonincendive field wiring, as defined under the Canadian Electrical Code, C22.1 or the National Electrical Code, NFPA 70.

Painting Valve

- It is not recommended that this valve be painted. Painting covers date codes and other labels that identify this valve.
- If the valve needs to be painted, a paint free of volitile organic compounds (VOC's) must be used. VOC's can damage valve o-rings, resulting in external gas leakage over time.
- During the painting process, use measures that will allow the valve's date code and other labeling information to be legible after the paint is dry.

Protection from Radiant Heat

- Radiant heat must be considered as a heat source that could result in an ambient temperature higher than the rating of this valve.
- Provide propor shielding to protect against radiant heat.

Dimensions Φ Upstream 1/4" NPT Tap Downstream 1/4" NPT Tap ပ D b

Туре	Order No.	Dimensions [inch] Dimensions [mm]			Weight [Ibs] [kg]				
		а	b	С	d	е	f	g	[9]
HPSV 10020/604	270890	2.95 75	8.82 224	6.30 160	6.02 153	9.84 250	2.09 53	2.52 64	13.2 6,0

Valve Leakage Test

This leak test procedure tests the valve seat sealing capabilities of the safety shutoff valve. Only qualified personnel should perform this test.

It is required that this test be done on the initial system startup, and then repeated at least annually. Possibly more often depending on the application, environmental parameters, and the requirements of the authority having jurisdiction.

Setup

This test requires the following:

- A) Test connection installed downstream of the safety shutoff valve to make the required 1/4" hose connection in step 4.
- B) A transparent glass of water filled at least 1 inch from the bottom.
- C) A proper leak test tube. An aluminum or copper 1/4" rigid tube with a 45° cut at the end that is then connected to a 1/4" flexible hose of some convenient length provides for a more accurate leakage measurement. However, a 45° cut at the end of the 1/4" flexible hose will suffice, but it will not likely be as accurate as the rigid tube.


Leak Test Procedure

Use the illustration below as a reference.

- Close the downstream manual shutoff valve, or safety shutoff valve.
- 2. Open the downstream test connection and connect the 1/4" flexible hose.
- 3. Provide for some time to allow potential leakage to charge the test chamber before measuring valve seat leakage.
- 4. Immerse the 1/4 in. tube vertically 1/2 in. (12.7 mm) below the water surface. If bubbles emerge from the 1/4" tube and after the leakage rate has stabilized, count the number of bubbles.
- If the number of bubbles exceeds 6 within 10 s, replace the valve.

After completing the above tests proceed as follows:

- 6. Verify that the downstream manual shutoff valve is closed.
- 7. Remove the flexible hose, and close the test connection.



Flow Curve 200 30 20 10 9 8 7 6 5 4 ∆p [mbar] 1,0 0,9 0,8 0,7 0,6 0,5 0,3 0,2 4 6 8 10 40 60 80 100 400 600 800 1000 $Vn [m ^3/h] Luft / Air / Aria dv = 1,00$

Pressure drop for other gases

To determine the pressure drop when using a gas other than natural gas, use the flow formula below and f value located in the table below to determine

the "corrected" flow rate in CFH through the valve for the other gas used. For example, when using propane, divide the volume (CFH) of propane required for the application by the calculated value

40 60 80 100

Ŭn [m ³/h] Erdgas/Natural gas/Gaz Naturel/Gas metano dv = 0,65

200

400 600 800 1000


20

f (f = 0.66 for propane). Use this "corrected" flow rate and the flow curve on the next page to determine pressure drop for propane.

Determining equivalent flow through valves using another gas

2





Type of gas	Density [kg/m³]	s.g.	f
Natural gas	0.81	0.65	1.00
Butane	2.39	1.95	0.58
Propane	1.86	1.50	0.66
Air	1.24	1.00	0.80



Accessories & Replacement

Replacement Coil			
Valve Type	Voltage	Order No.	
HPSV 10020/604 (Coil)	24 VDC	270888	

We reserve the right to make modifications in the course of technical development.



Karl Dungs, Inc.
3890 Pheasant Ridge Drive NE
Suite 150
Blaine, MN 55449, U.S.A.
Phone 763 582-1700
Fax 763 582-1799
e-mail info@karldungsusa.com
Internet http://www.dungs.com/usa/

Karl Dungs GmbH & Co. KG P.O. Box 12 29 D-73602 Schorndorf, Germany Phone +49 (0)7181-804-0 Fax +49 (0)7181-804-166 e-mail info@dungs.com Internet http://www.dungs.com